

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਬੁਢਲਾਡਾ
ਫੋਨ ਨੰਬਰ 01652-250042 ਈ-ਮੇਲ sdebudlada@gmail.com

No. 81


Date. 21/01/2026

To Whom it May Concern

SAFE DRINKING WATER CERTIFICATE

It is Certified that an inspection team headed by Sh. Rupal Kumar Garg
Outsource Junior Engineer (name of officers with designation) From W/S &
Sanitation S/d Budhlada (name of Depart/Office) took water sample from AKAL
ACADEMY CHAK BHAI KE (MANSA) on 21.11.2025 as per the testing report
submitted to this office, It is found that the AKAL ACADEMY CHAK BHAI KE
DISTRICT (MANSA) has safe drinking water & sanitation facilities for the
students and member of staff of the institutions.

This Safe Drinking Water & sanitation Certificate is valid up to 20/01/2027

Signature With Seal: 
ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ
ਵਾਟਰ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ
ਬੁਢਲਾਡਾ
Name: Sh. Rachhpal Singh
Designation: Sub Division Engineer

REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtsangrur@gmail.com

TEST REPORT


Name & Address of Customer : Sub Division Engineer Water Supply and Sanitation Sub Division, Budhlada		Customer Reference No.	No : 1655 Dated : 23/12/2025
		Sample Submitted by	
		Date of Sample Receipt	26/12/2025
		Analysis Starting Date	26/12/2025
		Analysis completion Date	27/12/2025
Discipline : Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTL/SNG/2526/00698	Date of Issue :	29/12/2025
Registration no.:	RWTL/SNG/REG2526/04208	Condition of Sample :	Unsealed
Collection Point:	House Tap Water (FHTC)	Quantity/Type of Bottle:	500 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Akal Academy, Chak Bhai Ke / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Budhlada	District :	Mansa
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur

----- End of the Test Report -----



TC-11386

TEST REPORT

Name & Address of Customer : SDE,DWSS, BUDHLADA BUDHLADA	Customer Reference No.	No : 1515 Dated : 21/11/2025
	Sample Submitted by	MR RUPAL
	Date of Sample Receipt	21/11/2025
	Analysis Starting Date	21/11/2025
	Analysis completion Date	22/11/2025
Discipline : Chemical Testing		
ULR No.:	TC113862500000252F	Sample Type : Treated Water
Test Report No.:	DWTL/MNS/2526/00255	Date of Issue : 22/11/2025
Registration no.:	DWTL/MNS/REG2526/02649	Condition of Sample : Unsealed
Collection Point:	Water Works	Quantity/Type of Bottle: 1000 ml / Transparent Plastic Bottle
Scheme/Source:	Chack Bhaike(CANAL)	Location/Depth : AKAL ACADEMY CHAK BHAIKE / NA
Village :	Chak Bhaike	Habitation : Chak Bhaike
Block:	Budhlada	District : Mansa
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.85@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	112	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Total Alkalinity (CaCO3)	24	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Total Hardness (CaCO3)	10	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	2.40	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	0.97	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	21.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

----- End of the Test Report -----